



University of Tehran

High Voltage Laboratory

Test Report

No: UTHV/891122

**Lightning impulse Voltage Test on 33kV
Current Transformer
Pars shar barez company production**



Test Report No UTHV/891122

Test Object: **Current transformer 33kV**

Type: **MC365**

Serial Number: **N/A**

Manufacturer: **Pars shar Barez Co.**

Test Performed on order of: **Pars shar Barez Co.**

Test Scope: **Type Test**

Test Procedure: **Lightning Impulse Voltage test according to standard IEC 60060**

Test Object Supplied on: **March 2011**

Test Performed During: **March 2011**

Test Result: **Indicated in Report**
The test result refers to the tested object only.





High Voltage Laboratory Participants:

Test leader:

Salman Mohseni

Head of Laboratory:

H. Mohseni, Prof.

Associate Dean:

K.Setarehdan, Dr.



Tehran, March 2011

Lightning Impulse Voltage Test on 33kV Current transformer




Contents

	pages
1. Description of test object	5
2. Scope of tests agreed upon	5
3. Dry Lightning impulse withstand voltage test	5
4. Summary	12

Annexes

1. Certificate of Impulse measuring system	13
--	----

This Report contains, 13 numbered pages
 12 figures
 2 tables





1. Description of test object

The test object was Current Transformer made by Pars Shar Barez Company

2. Scope of tests agreed upon

The accepted testing method was conforming to international standards:
IEC 60060 “

3. Dry Lightning impulse withstand voltage test

The purpose of the dry impulse withstand voltage test is to confirm that the insulator withstand the lightning overvoltage's that may occur in service.

Impulse voltage is produced by an impulse voltage generator in the laboratory. For insulators, the impulse voltage must be with positive and negative polarity, with the front time (T_1) equal to $1.2 \pm 30\% \mu s$ and with the time to half value (T_2) equal to $50 \pm 20\% \mu s$. Figure 1 shows the waveform of an impulse voltage.




Figure 1: The waveform of an impulse voltage

This arrangement was composed of four stages of impulse generator system Marx, 1.8 MV, 90 kJ made by HIGHVOLT (Germany). The figure 2 shows the scheme. Impulse shape was recorded with the transient recorder made by Dr. Strauss (Germany), cooperating with capacitive divider. The test procedure includes five impulses with positive polarity and five

Lightning Impulse Voltage Test on 33kV Current transformer



impulses with negative polarity. The test is OK, if flashover does not occur more than twice in each polarity.




Figure 2: Scheme of impulse generator and measuring system

Correction factor for the atmospheric conditions of the laboratory was **0.856**.

Table 1 show the parameters of positive voltage waveforms which applied to the insulator.

Table 1: Parameters of positive voltage waveform

No.	U_p (kV)	T_1 (μ s)	T_2 (μ s)	remark
1	169.6	1.12	51.7	Without flashover
2	169.6	1.12	51.6	Without flashover
3	169.7	1.12	51.7	Without flashover
4	169.5	1.11	51.7	Without flashover
5	169.6	1.12	51.5	Without flashover






Figure3: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V}=169.6$ kV, $T_1=1.12$ μs, $T_2=51.7$ μs




Figure 4: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V}=169.6$ kV, $T_1=1.12$ μs, $T_2=51.6$ μs

Lightning Impulse Voltage Test on 33kV Current transformer




Figure 5: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V}=169.7$ kV, $T_1=1.12$ μs, $T_2=51.7$ μs





Figure 6: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V}=169.5$ kV, $T_1=1.11$ μs, $T_2=51.7$ μs

Lightning Impulse Voltage Test on 33kV Current transformer






Figure 7: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V}=169.6$ kV, $T_1=1.12$ μ s, $T_2=51.5$

Table 2 shows the parameters of negative voltage waveforms which applied to the insulator.

Table 2: Parameters of negative voltage waveform

No.	U_p (kV)	T_1 (μ s)	T_2 (μ s)	remark
1	-169.4	1.12	51.6	Without flashover
2	-169.4	1.13	51.6	Without flashover
3	-169.3	1.11	51.7	Without flashover
4	-169.5	1.13	51.6	Without flashover
5	-169.6	1.12	51.6	Without flashover






Figure 8: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V} = -169.4$ kV, $T_1 = 1.12$ μs, $T_2 = 51.6$




Figure 9: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V} = -169.4$ kV, $T_1 = 1.13$ μs, $T_2 = 51.6$




Figure 10: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V} = -169.3$ kV, $T_1 = 1.11$ μs, $T_2 = 51.7$




Figure 11: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V} = -169.5$ kV, $T_1 = 1.13$ μs, $T_2 = 51.6$






Figure 12: Voltage waveforms of dry impulse withstand voltage, impulse 1; $\hat{V} = -169.6$ kV, $T_1 = 1.12$ μ s, $T_2 = 51.6$



The dry positive impulse withstand voltage is +169.7kV.

The dry negative impulse withstand voltage is -169.6kV.

4. Summery

All tests have got satisfactory results



Annex 1

Certificate of Impulse measuring system

DEUTSCHER KALIBRIERDIENST **DKD**

Kalibrierlaboratorium für elektrische Messgrößen / Hochspannungsmesseinrichtungen
Calibration laboratory for electrical measuring quantities / high voltage measuring systems

Akkreditiert durch die / *accredited by the*
Akkreditierungsstelle des DKD bei der
PHYSIKALISCH-TECHNISCHEN BUNDESANSTALT (PTB)



HIGHVOLT Prüftechnik
Dresden GmbH



Kalibrierschein
Calibration Certificate

Kalibrierzeichen
Calibration label

536
DKD-K-24501
01-12

Gegenstand
Object
Messsystem für 1800 kV Blitzstoß- und
1300 kV Schaltstoßspannung
*1800 kV-Lightning Impulse Voltage / 1300 kV
Switching Impulse Voltage Measuring System*

Hersteller
Manufacturer
HIGHVOLT Prüftechnik Dresden GmbH
Hochspannungsgeräte Porz GmbH
Dr. Strauss Systemelektronik GmbH

Typ
Type
SMCF 440/1800 / H 391 / TR-AS 100-10

Fabrikat/Serien-Nr.
Serial number
882 392 / 882 393 / 501

Auftraggeber
Customer
University of Tehran
Institute of Electrical Engineering
Kargar Shomali
IR-14399 Teheran - Iran

Auftragsnummer
Order No.
521 320

Anzahl der Seiten des Kalibrierscheines
Number of pages of the certificate
22

Datum der Kalibrierung
Date of calibration
2001-12-02

Dieser Kalibrierschein darf nur vollständig und unverändert weiterverbreitet werden. Auszüge oder Änderungen bedürfen der Genehmigung sowohl der Akkreditierungsstelle des DKD als auch des ausstellenden Kalibrierlaboratoriums. Kalibrierscheine ohne Unterschrift und Stempel haben keine Gültigkeit.
This calibration certificate may not be reproduced other than in full except with the permission of both the Accreditation Body of the DKD and the issuing laboratory. Calibration certificates without signature and seal are not valid.

Stempel <i>Seal</i> 	Datum <i>Date</i> 2001-12-14	Leiter des Kalibrierlaboratoriums <i>Head of the calibration laboratory</i> Dr.-Ing. Maucksch	Bearbeiter <i>Person in charge</i> Dr.-Ing. Maucksch
----------------------------	------------------------------------	---	--

HIGHVOLT Prüftechnik Dresden GmbH, Marie-Curie-Str. 10, 01139 Dresden, Tel. ++49 351 8425 668, Fax ++49 351 8425 610



Lightning Impulse Voltage Test on 33kV Current transformer